

# Operating Manual

LogBox AA Data Logger

**0568 0033-03**

**0568 0034-03**



## CONTENTS

1	Foreword.....	1
2	GENERAL ADVICE .....	1
2.1.	Labels.....	1
2.1	Warning Advice .....	1
2.2	Security Advices.....	2
3	Introduction .....	2
3.1	Memory Capacity .....	2
3.2	Input Signals .....	3
3.3	Data Acquisitions (Logging) .....	3
4	Operation .....	3
4.1	Status Indicators (LEDS).....	3
5	LogChart II .....	4
5.1	Installing LogChart II .....	4
5.2	Running LogChart II .....	4
6	Optical Interface IR-LINK 3 .....	4
7	Configuring the Logger .....	5
7.1	General Information Field.....	5
7.2	Acquisition Field .....	5
7.3	Start Logging Field .....	6
7.4	Stop Loggings .....	6
7.5	Channels Field .....	6
8	Electrical Connections .....	7
8.1	IP65 Model .....	7
8.2	IP67 Model .....	7
8.3	Input Connections .....	8
8.4	External Battery Switch .....	8
8.5	DIGITAL INPUT (DI) .....	9
8.6	INSTALLATION RECOMMENDATIONS .....	9
9	Data Download and Visualization .....	9
9.1	Graph window .....	9
9.2	General information table .....	10
9.3	Acquisitions Table Window .....	10
9.4	Visualiszing the Data.....	10
10	Monitoring Acquisitions .....	10
11	OBSERVATIONS.....	11
12	MOST FREQUENTLY PROBLEMS.....	11
13	Questions? .....	11

## 1 FOREWORD

Dear customer,

We thank you for having purchased the **LogBox-AA Data Logger** and are very glad that you decided in favour of a product of B+B Thermo-Technik GmbH. We hope this product will fully satisfy you and will assist you effectively in your work.

This Device has been developed to be technically highly up-to date. This product has been designed in accordance with the regnant European and German national directives and rules. For a proper and effective usage of the product the customer shall observe the following Operating Instructions. In the case that against one's expectations any troubles occur which you cannot resolve yourself, please contact our service centers or your salesperson. We go after giving you rapid and competent help to minimize the risk of long-time outfalls.





The following operating Instruction is an indispensable part of this Product. It contains important advices for the starting up and further use of the device











## 2 GENERAL ADVICE

This documentation contains information which must be paid in attention to assure a highly effective and secure use of the supplied product. Please read through the following instructions and make yourself familiar with the handling of the product before you insert it in your processes. Keep this document always readily to hand so you can consult it by need.

### 2.1. Labels

Symbol	Meaning	Description
	Advice	It is necessary to read the following advice before beginning the operations. The used symbols in the manual acts first as eye catcher for security risks. The symbols do not replace the security advice. The text must be read to the end
	Necessary to observe	This symbol designates important advice and tips that are necessary for the success a work step. They must be followed to get good results

### 2.1 Warning Advice

Symbol	Meaning	Symbol	Meaning
	This symbol advises the user of danger for persons, material, or environment. The text gives information that must be necessarily followed to avoid any risks		Caution against electromagnetic fields (BGV A8, GUV-V A8/W12)
	Caution against hot surfaces (BGV A8, GUV-V A8/W26) and hot liquids or substances		Caution against severe cold (BGV A8, GUV-V A8/W17)
	Caution against liquids and hot substances		Caution against dangerous high electrical voltage (BGV A8, GUV-V A8/W08)
	Caution against dangerous ex-plosive substances (BGV A8, GUV-V A8/W02)		Caution against dangerous ex-plosive atmosphere (BGV A8, GUV-V A8/W21)
	Caution against mobile engines (W29) Caution against moving parts		Electronic waste

# LogBox-AA Data Logger

## 0568 0033-03 / 0568 0034-03



## 2.2 Security Advices

B+B Thermo-Technik GmbH assume no liability for damages occurred through failure to observe these security advices. A usage non conforms to the instructions given in this manual can damage the device

### BODY AND PROPERTY DAMAGES



The national and local standards for electrical installations must be strictly observed.  
The use of the device is strictly reserved / restricted to properly schooled / qualified operators.

The system is not adequate for use in atmosphere with explosion danger.

Do not use the system in a high electric or magnetic field area

### ENSURING OF PRODUCT SECURITY



The system must be operated only within the limits given in the technical Data  
Exposing the system to hot temperatures (higher than the operating temperature) will cause damages in the electronic circuits and also damage the housing

### USAGE ACCORDING TO PURPOSE



Please use the product only for the purposes for which it is conceived. In case of doubt, please first contact B+B Thermo-Technik GmbH

### DISOPOSAL



Please return the device to B+B Thermo-Technik GmbH after expiration of its lifetime

## 3 INTRODUCTION

**LogBox-AA** is an electronic data logger with two analog input channels. Values measured by these channels (data) are stored in the logger electronic memory (acquisitions) for later download to a PC for visualization and analysis in the form of tables or graphs. Data can be easily exported to spreadsheets.

The **LogChart-II** is the software used to configure the logger, download, and visualize data. The logger configuration allows define the logger operation mode, including the **start/stop** time of data acquisition. Other parameters such as signal input type, Logging interval, etc., are easily selected through the **LogChart-II** software.

The **LogBox-AA** also provides a signal for commanding an external power supply (battery) of a device connected to the logger. This feature allows that external device, such as a transmitter, be powered only during the measurement sample time, thus extending the service life of these external batteries applications, such as spreadsheet programs

### 3.1 Memory Capacity

64 k Model: Allows up to 64.000 records.

Memory capacity is always shared between enabled channels. In case there are two channels enabled, each gets 50 % of the memory available. When only a single channel is enabled, it has the entire memory at its disposal.

Memory capacity is indicated on the identification label placed on the logger case.

**LOGBOX-AA IP67**  
ELECTRONIC DATALOGGER  
MEMORY: 64.000 LOGGINGS

Figure 1 IDENTIFICATION LABEL

### 3.2 Input Signals

The input channels 1 and 2 measure analog electric signals, which can be Pt100, Thermocouple (J, K, T, E, N, R, S or B), voltage (0 to 50 mV or 0 to 10 V) or current (0 to 20 mA or 4 to 20 mA), according to user-defined settings.



Besides configuration performed through the software, the definition of input signal requires two internal jumpers to be configured

### 3.3 Data Acquisitions (Logging)

Data can be acquired through different modes. The logger can be configured to perform a single measurement within a time interval storing the value read or perform ten measurements within the time interval and store the mean of values measured. Yet, it can store the minimum or maximum values read in the interval

## 4 OPERATION

The logger operation mode is user-defined in the **LogChart-II** software. To access or change this configuration, the IR-LINK3 interface is required. The user must install the **LogChart-II** software on a computer and run the logger configuration according to instructions defined in the **LogChart-II** installation section of this manual.

After configuration and input electric connections are made, the device is ready to measure and log input signals. The status indicator shows the logger current status.

### 4.1 Status Indicators (LEDS)

The Status Indicators (see Fig. 2) are located on the logger front panel. They indicate the current working conditions of the unit.

- **LOG Indicator (Logging):** While in stand-by (not logging) or after a series of acquisitions is ended, it flashes once at every four seconds. During login it flashes twice at every four seconds.
- **AL Indicator (alarm):** Alerts the user regarding alarm conditions. Whenever an alarm situation takes place, it will flash once at every four seconds, until a new configuration is applied to the logger




Figure 2 LED INDICATORS AND IR COMMUNICATION

## 5 LOGCHART II

### 5.1 Installing LogChart II

The LogChart II is the software provided with the logger to allow for configuration and data collection. To install the LogChart II, execute the LC\_II\_Setup.exe program available on our website. The installation wizard will then guide you throughout the installation process.

### 5.2 Running LogChart II

Start the program. The main window will appear on the screen, as in Fig. 3.




Figure 3 LOGCHART II MAIN WINDOW

The LogChart II requires a communication port to talk to the logger. Select one and connect the corresponding wand IR-LINK3 to it. Click on the menu Port. Clicking on the menu Port, all free communication ports available in the computer will be listed. The chosen port will be remembered next times the LogChart II is initiated.

When the selected port is successfully opened, the LogChart II initial screen is opened, enabling the buttons below



Figure 4 BUTTONS ENABLED WHEN THE COMMUNICATION PORT OF CHOICE IS  
VALID

In case the user wants to stop the process while data logging is running, the button "Stop" must be pressed



## 6 OPTICAL INTERFACE IR-LINK 3

Configuring, monitoring, or downloading data from the logger through LogChart-II requires that the **IR-LINK3** communication interface be connected to your PC. This interface is sold separately.

The **IR-LINK3** interface sends and receives data to/from the logger through infrared signals. Windows will request the proper driver installation, which is found on our website. After installation is completed, the **IR-LINK3** interface is recognized whenever it is connected to the PC. After the USB driver installation, the LogChart II must be opened again. In the "Port" menu, choose the same port selected for the optical interface communication using the menu Port.

## 7 CONFIGURING THE LOGGER

Make sure the IR-LINK3 wand is connected to the PC port selected. The interface must be pointed towards the logger communication window (see Figure below) at a distance of about 15 cm.





Figure 5 INFRARED INTERFACE POSITION

Click the button  to start the communication between the logger and the software; the Parameters Configuration window is then displayed (Fig. 6), showing the current configuration and information about the logger. New configuration parameters defining the operation mode for a new application can be entered. The user can also obtain general information about the device.

The fields of the configuration window are described below




Figure 6 Configuration Window

### 7.1 General Information Field

General information on the top of the screen informs the model, serial number, logger current date/time, PC date/time, firmware version (logger model version), memory capacity and used memory. This information is displayed in the upper part of the LogChart-II configuration screen. The time is constantly updated in this screen, provided that the logger and the PC are communicating

### 7.2 Acquisition Field

- **Period:** It determines the interval between readings in the hh:mm:ss format. New data is stored in the logger memory after each time interval. In the **Instantaneous** reading mode, the value of the interval between acquisitions is the same as the time interval between measurements. For **Average**, **Minimum** and **Maximum** readings, the logger executes 10 readings within this interval.
- **External Battery Switch time:** Defines the time when the logger turns on the power supply, before proceeding with any reading. This time is limited to 10 seconds and must be less than half of the interval between readings.
- **Estimated time:** It informs the estimated time for the accomplishment of programmed readings based on the logging "Interval" and on the number of programmed readings.

# LogBox-AA Data Logger

## 0568 0033-03 / 0568 0034-03



- **Daily Repetition:** Allows loggings to be repeated every day, for example, recording data from 8 AM to 5 PM day after day. The start and stop times are defined in the fields "Start time" and "Stop time."

### 7.3 Start Logging Field

- **Immediately:** The logger starts logging as soon as the configuration is applied. Not valid when the option 'Daily Repetition' is selected.
- **Day / Hour:** Logging starts at a defined date and time. The date defined is used for the Daily Repetitions option as well.
- **With Start Button:** Starts and stops logging by pressing the Star button for two seconds.
- **Digital Input:** Starts readings when the digital input is activated (closed) and stops readings when the digital input is deactivated (open).

### 7.4 Stop Loggings

- **At Full Memory:** Loggings can be stored up to the full memory capacity is reached.
- **Wrap around:** Logging never stops. The LogBox-AA will keep on recording the readings and when the memory is full it will overwrite the oldest record in a circular or wrap around manner.
- **After a defined number of readings:** The logger will stop logging after the number of readings here defined is reached. Not valid when the option 'Daily Repetition' is selected
- **Day / Hour:** The LogBox-AA will stop logging at the user-defined date and time. Not valid when the option 'Daily Repetition' is selected.

### 7.5 Channels Field

By selecting the "Channels" option, the user is able to choose the individual settings for each input channel, as Fig. 7 shows




Figure 7 Channel Configuration

The Parameters are:

- **Tag:** Defines a name (up to 8 characters) for identifying the variable to be measured.
- **Inputs:** The signal applied to the logger input is defined here. The list shows all the input options available. The selected option must be in accordance with the internal configuration of the jumper, as Table 1 shows.
- **Unit:** Defines the variable unit.
- **Scale:** Defines the range, in engineering units, for representing the input variable measured. Adjustable from -32000 to +32000 for 4-20 mA, 0-20 mA, 0-50 mV and 0-10 inputs, for the remaining input the scale is fixed.
- **Offset:** Allows fine offset corrections on the measured value.
- **Value:** Defines readings recording mode. The following Options are available:



# LogBox-AA Data Logger

## 0568 0033-03 / 0568 0034-03



- **Instantaneous:** The instant value read at the logging time.
- **Average:** Ten readings at each reading interval. The average value of readings is the value recorded.
- **Minimum:** Ten readings at each reading interval. The lowest value found is recorded.
- **Maximum:** Ten readings at each reading interval. The highest value found is recorded.
- **Alarm:** defines a limit range of variables measured that, once exceeded, trigger the alarm. Once activated, the alarm LED indicator stays so even after the alarm-triggering situation has ceased.
  - **LOW** defines the minimum value under which the alarm is triggered.
  - **HIGH** defines the maximum value above which the alarm sensor is triggered.

After filling all the fields, send the configuration to the logger by clicking on the button



New settings and PC current date/time are then sent to the logger.

## 8 ELECTRICAL CONNECTIONS

Only the input connections and the External Battery Switch (when used) are needed. The logger is exclusively powered by its internal battery. In the IP65 models, the inputs and the signal for activating the external power supply are located inside the logger case, which must be opened for accomplishing the connections

In the IP67 model, proper connectors are provided for this purpose, as shown in Fig. 9.

### 8.1 IP65 Model

Open the logger's cover to get access to the block terminals and the configuration jumpers. Connection cables must pass through the compress fitting located at the bottom of the case. Fig. 8 shows the internal terminals distribution

Channel 1:	CN1 connector – Terminals 1, 2 and 3
Channel 2:	CN1 connector – Terminals 4, 5 and 6
External Battery Switch	CN2 connector – Terminals 7, 8 and 9
Digital Input	CN2 connector – Terminals 7, 10 and 9




Figure 8 IP 65 Model - Connections



Make sure that the compress fitting is perfectly tightening the cables, thus assuring proper IP65 protection: (totally dust-tight and protected against water jets).

### 8.2 IP67 Model

In the IP67 version, an M8 connector is provided for signal input. Two connectors provide external access to the input channels, as shown in Fig. 9. The cables are supplied with the logger.



The case cover should not be opened unless battery replacement is required. If this is the case, the cover must be properly tightened back in its place such as to assure the IP67 protection.

# LogBox-AA Data Logger

## 0568 0033-03 / 0568 0034-03




IP67 - Totally dust-tight and protected from temporary immersion in water.

Channel 1 cable (right)	Connection
Brown	CN1-3
Blue	CN1-2
Black	CN1-1

Channel 2 cable (left)	Connection
Brown	CN1-6
Blue	CN1-5
Black	CN1-4

Figure 9 IP67 external connectors



### 8.3 Input Connections

Both models have the same input connections schema:





Figure 10 Input Signal Connections

Before using the logger, the internal jumpers positioning must be set according to the input type used. The factory setting of these jumpers is for measurement of Pt100 / Thermocouple / 0-50mV signals.

Input signal	CHANNEL 1 J1 position	CHANNEL 2 J2 Position
4-20 mA / 0-20 mA	A	A
Pt100 / Thermocouple / 0-50 mV	B	B
0-10 V	C	C

Tabelle 1 J1 and J2 Positions



### 8.4 External Battery Switch

The example in (Fig. 11) below shows the usage of the external battery switch for commanding the power supply of external devices. Channel 1 is configured to 4-20mA input signal. A battery is used to provide power to the 4-20 mA loop. The battery switch "turns on" the power to the loop a moment (defined in the configuration) before the measurement is taken, enabling the transmitter (pressure, temperature, etc) to start up and stabilize the output.





Figure 11 Ex of using the external Battery switch

Figure 12 Ex of using the Battery switch



### 8.5 DIGITAL INPUT (DI)

The Digital Input that can be used to guide the logger readings is available in terminals 7 (-) and 10 (+) of CN2.

### 8.6 INSTALLATION RECOMMENDATIONS

- Signal wires should be installed in grounded conduits and away from power or contactor wires.
- Instruments must be powered only by an exclusive power supply.
- System failure should always be considered when designing a control panel to avoid irreversible damage to equipment or people.
- Installing RC filters (47 R and 100 nF, serial) is strongly recommended at contactor coils or any other inductors

## 9 DATA DOWNLOAD AND VISUALIZATION

The transference of data to a PC is accomplished by using the LogChart II software. Data can be collected anytime and saved in files for future analysis (menu "File Save" or "File Save as"). Help can be accessed from the LogChart-II software when necessary.

Offloading data: data offload is accomplished by clicking on the button 

Or using the LogChart -II menu. During data transfer, a status bar indicates remaining data to be transferred. Data downloading time is proportional to the number of readings logged. At the end of data transference, the Graph window is displayed.

### 9.1 Graph window

The Graph is a convenient tool for analysis. It enables the logger acquisitions to be read in the form of a "values x time" graph. As one moves the mouse in the chart area, the time, and the value of the records of each channel are shown in the field located in the bottom of the window. Zooming in and out are implemented. It is possible to select an area by clicking and dragging the mouse, thus creating a zoom region, starting at the upper left position of the region of interest




Figure 13 Graph Window




The command **DOWNLOAD** acquisitions does not interrupt the process of data logging and reading.

Other two windows can be easily opened: General information window and Tables window

### 9.2 General information table

Displays information about the logger that registered data: its features and configurations, and details about data acquired



General Information	
LogBox	
Model:	LogBox AA
Serial Number:	5038302
Firmware Version:	1.09
Memory Capacity:	16382 loggings
Boiler (Bar)	
Input:	4-20mA
Value:	Instantaneous Value
Offset:	0
Temp (°C)	
Input:	Pt 100
Value:	Instantaneous Value
Offset:	0
Logging Information	
Title:	LogBox
Interval between readings:	10 sec
Total Number of Loggings:	10076
Start Logging:	Immediately
Stop Logging:	At full memory
Download Time:	quinta-feira, 2 de março de 2006 at 13:47:29
First logging:	quinta-feira, 2 de março de 2006 at 10:58:41
Last logging:	sexta-feira, 3 de março de 2006 at 14:57:51

Figure 14 General information table


### 9.3 Acquisitions Table Window

Data acquired by one or both input channels (user-defined) are displayed in engineering units in a table format. The table displays register number, date/time and the record values

### 9.4 Visualizing the Data

Three windows supporting data visualization: Graph, Acquisitions Table and General Information windows. Data can be originated from direct reading from the logger or from a file previously recorded in a computer.


Once the windows are open, data can be saved in a file (.lch), printed on a graph or exported to a text file (.txt or .dat).



Record Nr.	Time	Date	Boiler (Bar)	Temp (°C)
02852	18:53:51	2/3/2006	10,6	69,3
02853	18:54:01	2/3/2006	10,6	69,2
02854	18:54:11	2/3/2006	10,6	69,2
02855	18:54:21	2/3/2006	10,6	69,2
02856	18:54:31	2/3/2006	10,6	69,2
02857	18:54:41	2/3/2006	10,6	69,2
02858	18:54:51	2/3/2006	10,6	69,2
02859	18:55:01	2/3/2006	10,6	69,2
02860	18:55:11	2/3/2006	10,6	69,2
02861	18:55:21	2/3/2006	10,6	69,2
02862	18:55:31	2/3/2006	10,6	69,2
02863	18:55:41	2/3/2006	10,6	69,2
02864	18:55:51	2/3/2006	10,6	69,2
02865	18:56:01	2/3/2006	10,6	69,2
02866	18:56:11	2/3/2006	10,6	69,2
02867	18:56:21	2/3/2006	10,6	69,3
02868	18:56:31	2/3/2006	10,6	69,3
02869	18:56:41	2/3/2006	10,6	69,2
02870	18:56:51	2/3/2006	10,6	69,2
02871	18:57:01	2/3/2006	10,6	69,2
02872	18:57:11	2/3/2006	10,6	69,2

Figure 15 Acquisition table

## 10 MONITORING ACQUISITIONS

To visualize current measurements in a graph format, use the Monitor On-Line (Fig. 16) command by clicking on the button:  while pointing the IR-LINK3 interface to the logger.




Figure 16 Online Monitoring Graph

## 11 OBSERVATIONS



The logger is an electronic device and some basic care is required:

- When opening the device for battery replacement or connecting sensors avoid touching the circuit for not causing damages resulting from static electricity.
- When the device is opened, avoid liquid and/or dust contact.
- Use a screwdriver to open the case cover.
- Pay attention to batteries polarity: The positive terminal should be placed directed towards the center of the device.
- Worn batteries should not be recharged, dismantled or incinerated. After use, batteries must be disposed according to local legal rules.
- After placing batteries back to the logger, make sure the cover is firmly attached to the socket.

## 12 MOST FREQUENTLY PROBLEMS

### The LED is not flashing

- The LED flashing light is intentionally weak, and it can be difficult to see it in illuminated environments. Make sure it is not flashing at all.
- Make sure the battery is installed correctly; Make sure the battery is not discharged

### Communication with the logger fails

- Make sure the COMM port is selected correctly and there is no other program using the same port during communication attempts
- Make sure there is no physical obstacle blocking the infrared signal; Make sure the cable is well connected to the PC port
- Make sure the port selected does not present any problem

## 13 QUESTIONS?


For further information about this or other products of B+B Thermo-Technik GmbH please do not hesitate to contact us at:

B+B Thermo-Technik GmbH  
Heinrich-Hertz-Straße 4  
78166 Donaueschingen  
Deutschland

Tel.: +49 771 83160  
Fax: +49 771 831650

E-Mail: [info@bb-sensors.com](mailto:info@bb-sensors.com)  
[www.bb-sensors.com](http://www.bb-sensors.com)

## 14 TECHNICAL SPECIFICATIONS

Features	Description																										
<b>Inputs</b>	<p>Thermocouples according to DIN EN 60584 Pt100 according to DIN EN 60751</p> <table border="1"> <thead> <tr> <th>TYPE</th><th>CHARACTERISTICS</th></tr> </thead> <tbody> <tr> <td>J</td><td>Range: -50 to 760 °C (-58 to 1400 °F)</td></tr> <tr> <td>K</td><td>Range: -90 to 1370 °C (-130 to 2498 °F)</td></tr> <tr> <td>T</td><td>Range: -100 to 400 °C (-148 to 752 °F)</td></tr> <tr> <td>N</td><td>Range: -90 to 1300 °C (-130 to 2372 °F)</td></tr> <tr> <td>R</td><td>Range: 0 to 1760 °C (32 to 3200 °F)</td></tr> <tr> <td>S</td><td>Range: 0 to 1760 °C (32 to 3200 °F)</td></tr> <tr> <td>B</td><td>Range: 150 to 1820 °C (32 to 3308 °F)</td></tr> <tr> <td>Pt100</td><td>Range: -200.0 to 650.0 °C (-328 to 1202 °F)</td></tr> <tr> <td>0-50 mV</td><td>Linear. Programmable range of -32768 to 32767</td></tr> <tr> <td>4-20 mA</td><td>Linear. Programmable range of -32768 to 32767</td></tr> <tr> <td>0-20 mA</td><td>Linear. Programmable range of -32768 to 32767</td></tr> <tr> <td>0-10 VDC</td><td>Linear. Programmable range of -32768 to 32767</td></tr> </tbody> </table>	TYPE	CHARACTERISTICS	J	Range: -50 to 760 °C (-58 to 1400 °F)	K	Range: -90 to 1370 °C (-130 to 2498 °F)	T	Range: -100 to 400 °C (-148 to 752 °F)	N	Range: -90 to 1300 °C (-130 to 2372 °F)	R	Range: 0 to 1760 °C (32 to 3200 °F)	S	Range: 0 to 1760 °C (32 to 3200 °F)	B	Range: 150 to 1820 °C (32 to 3308 °F)	Pt100	Range: -200.0 to 650.0 °C (-328 to 1202 °F)	0-50 mV	Linear. Programmable range of -32768 to 32767	4-20 mA	Linear. Programmable range of -32768 to 32767	0-20 mA	Linear. Programmable range of -32768 to 32767	0-10 VDC	Linear. Programmable range of -32768 to 32767
TYPE	CHARACTERISTICS																										
J	Range: -50 to 760 °C (-58 to 1400 °F)																										
K	Range: -90 to 1370 °C (-130 to 2498 °F)																										
T	Range: -100 to 400 °C (-148 to 752 °F)																										
N	Range: -90 to 1300 °C (-130 to 2372 °F)																										
R	Range: 0 to 1760 °C (32 to 3200 °F)																										
S	Range: 0 to 1760 °C (32 to 3200 °F)																										
B	Range: 150 to 1820 °C (32 to 3308 °F)																										
Pt100	Range: -200.0 to 650.0 °C (-328 to 1202 °F)																										
0-50 mV	Linear. Programmable range of -32768 to 32767																										
4-20 mA	Linear. Programmable range of -32768 to 32767																										
0-20 mA	Linear. Programmable range of -32768 to 32767																										
0-10 VDC	Linear. Programmable range of -32768 to 32767																										
<b>Input Impedance</b>	<p>0-50 mV, Pt100 and thermocouples: &gt;10 MΩ 0-10 V: &gt; 1 MΩ 0 to 20 mA and 4 to 20 mA: 100 Ω + 2 Vdc</p>																										
<b>Accuracy</b>	<p>Thermocouple J, K and T: 0.25 % of max. range ±1 °C; Thermocouple N, R, S, B: 0.25 % of max. range ±3 °C; Pt100: 0.2 % of the max. range; mA, mV and V: 0.2 % of the max. range.</p>																										
<b>Memory capacity</b>	64.000 (64 k) loggings.																										
<b>Measuring Interval</b>	Minimum: 1 second, maximum: 18 hours																										
<b>Power Supply</b>	3.6 V lithium battery (1/2 AA)																										
<b>External battery switch time</b>	Max 10 Seconds																										
<b>Typical battery life</b>	200 days with one weekly download and 5 minutes measuring interval. Battery life depends heavily on data retrieval frequency																										
<b>Working temperature</b>	-40 °C to 70 °C.																										
<b>Protection Index</b>	IP65 and IP67 models (see lateral label on product)																										
<b>Material</b>	ABS with polycarbonate film case; Polycarbonate film																										
<b>Dimensions</b>	<p>60 x 70 x 36 mm</p>  <p>ALL DIMENSIONS IN mm</p>																										
<b>PACKAGE CONTENTS</b>	<p>Besides this manual, the user must check if the items below accompany the product.</p> <ul style="list-style-type: none"> <li>The electronic logger LogBox-AA</li> </ul> <p>Two cables for sensor wiring (IP67 model only)</p>																										